

**PRIVATE SEWAGE SYSTEM  
INSPECTION REPORT for Dunn County**

Name	Tom Cervenka	
Address	2014 Wilson St. #4	
City	Menomonie	
State & Zip	WI	54751

PLUMBER:	CST:
Todd Sinz	Henry Grote

E Property Address/City	N5147 410 <sup>th</sup> St. Menomonie, WI 54751
Town of	MENOMONIE
Legal	SE-NW 34-28-13
Subdivision	
CSM #	
Sanitary permit #	<b>455076</b>
State Plan ID #	
Parcel tax #	281334.00601
Computer #	016-1151-06

GENERAL INFORMATION

CST BM Elev.:	Insp. BM Elev.:
BM Description: Nail in 3' oak tree	

ELEVATION DATA

STATION	ELEVATION	ELEVATION
Benchmark		100'
Well		
Bldg. Sewer		91.59
S/Ht Inlet	Pole bldg.	98.43
S/Ht Outlet		91.03
Dt. Inlet		
Dt. Bottom		86.78
Header/Man		
Dist. Pipe		
Bottom of system		
NE infiltrator		97.01
SE infiltrator		96.97
NW infiltrator		96.97
SW infiltrator		97.01

TANK INFORMATION

TYPE	MANUFACTURER	CAPACITY
Septic	Huffcutt	1250
Dosing	Huffcutt	750

TANK SETBACK INFORMATION

TYPE	P/L	WELL	BLDG	VENT TO AIR INTAKE
Septic	158'	49'	9'	
Dosing	140'	42'	22'	

PUMP/SIPHON INFORMATION

Manuf/Model #	Little Giant 9EH		
Lift	Friction Loss	System Head	TDH Ft.
Forcemain	Length	Dia.	Dist. to Well

Bottom of system		
NE infiltrator		97.01
SE infiltrator		96.97
NW infiltrator		96.97
SW infiltrator		97.01

SOIL ABSORPTION SYSTEM

Dispersal Cell Information	Manuf.	Quik 4	Width	3'	Length	68'	No. of Cells	2
Setback	Type of System		P/L	Bldg	Well	Lake/Stream		
Information	Conventional Trench		10'	47'	115'			

DISTRIBUTION SYSTEM

Header/Manifold	Distribution pipe(s)	X Hole Size	X Hole Spacing
Length	Dia. Dia. Spacing		

WI FUND: \_\_\_\_\_ Yes \_\_\_\_\_ **X** No \_\_\_\_\_ Maybe

COMMENTS: Oranco Biotube filter installed.

New House/Double Wide	<b>X</b>
New Mobile Home	
New Other	
Replace/Repair/Reconnect	

9/07/04  
Date

*Alex Sherrill*  
Inspector's Signature

220750  
Cert. No.

15.67 ACRE  
PARCEL



SCALE: 1" = 40'

